

Certificate of Compliance

Certificate Number 130206 - E198546
Report Reference E198546, December 23rd, 2005
Issue Date 2006 February 13

Page 1 of 2



**Underwriters
Laboratories Inc.®**

Issued to: **GEFRAN SPA**
VIA SEBINA 74
25050 PROVAGLIO D'ISEO BRESCIA ITALY

*This is to certify that
representative samples of*


Programmable controllers,
Cat. No. **GFX-M2, GFX-S2, GFX-E2,** followed by **B15, 5, 10, 15, R, RR or CC,**
followed by **0, 230 or 440,** followed by **M, P, C or D,** followed by **0, D, R or C,**
followed by **RR,** followed by **P,** followed by **0, C0, CV, IM or PO**

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **UL 508 - Industrial Control Equipment**
CSA C22.2 No. 14-M05 - Industrial Control Equipment

Additional Information: See Addendum for Electrical Ratings

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Nadia Andreola*

Nadia Andreola, Engineer

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Italy, you may call +39 079 2636600.

Reviewed by: *Matteo Redaelli*

Matteo Redaelli, Team Ldr Engineer

UL International Italia Srl

Certificate of Compliance

Certificate Number 130206 - E198546
Report Reference E198546, December 23rd, 2005
Issue Date 2006 February 13

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL, cUL requirements.

RATINGS:

Power supply:	230 or 440 Vac, 5 A up to 13A, 50-60Hz
Control input:	24 Vdc \pm 25%, 5W max. Remote Class 2 Source or limited voltage limited current.
Logic input	24 Vdc, 8 mA
Output ratings:	Relay: 250 Vac, 3A, resistive. Three relays maximum provided
	Logic: 24 Vdc, 35 mA One logic output + Two relays provided
	Continuous: 0-10 V 0-20 mA
Operating Surrounding air:	40°C

Issued by:

Nadia Andreola, Engineer

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International Italia Srl

Reviewed by:

Matteo Redaelli, Team Ldr Engineer

UL International Italia Srl